Recc all piping to be sized per ASHRAE F36.

POWER SUPPLY
CONTROL SIGNAL FROM BCS–1
PUMP POWER SUPPLY
BOILER CONTROLS
TDR
B–1

POWER SUPPLY
CONTROL SIGNAL FROM BCS–1
PUMP POWER SUPPLY
BOILER CONTROLS
TDR
B–2

HWR
T
3–10X PIPE DIA. STRAIGHT PIPE ONLY

ET
BY PASS
P
CWMU
HWS
PSD
AV
AS

POWER SUPPLY
CONTROL SIGNAL TO B–1
CONTROL SIGNAL TO B–2
BOILER CONTROL SYSTEM
BCS–1
OAS (OPTIONAL)

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

REV	DESCRIPTION	BY	DATE
A	RELEASED	RSG	05/28/08

THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF FLOWTHERM SYSTEMS, A DIVISION OF CHC, CALIFORNIA HYDRONICS CORP., COPIES ARE ISSUED IN STRICT CONFIDENCE AND SHALL NOT BE REPRODUCED OR COPIED, OR USED AS THE BASIS FOR THE MANUFACTURING, INSTALLATION OR SALE OF PRODUCT WITHOUT PRIOR WRITTEN PERMISSION OF CHC.

PROJECT NAME:
PROJECT LOCATION:
ENGINEER:
CUSTOMER:

DRAWING TITLE:
HYDRONIC PRIMARY/SECONDARY – 2 ATMOSPHERIC BOILERS, SEPARATE PRIMARY PUMP POWER, NO TEMP PROTECTION, WITH 2 SYSTEM PUMPS

DRAWING No. H–PS–101–2XX–2 REV A

DRAWN BY	DATE	TOLERANCES UNLESS OTHERWISE SPECIFIED CHECKED	APPROVED	DEC.	ANGLE	SIZE	SCALE
D.K	05/23/08			.500"	5'	D	NTS

CHC