



Recc all piping to be sized per ASHRAE F36

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM F INLET TEMPERATURE BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

PROJECT NAME:		PROJECT LOCATION:		DRAWING TITLE:	
PROJECT NO.:		ENGINEER:		HYDRONIC PRIMARY/SECONDARY - 2 ATMOSPHERIC BOILERS, CIRCUIT SETTER PROTECTION, WITH SYSTEM PUMP	
DATE:		BY:		DRAWING No.:	
DESCRIPTION:		RSG 05/28/08		H-PS-100-2CS-1	
				TOLERANCES UNLESS OTHERWISE SPECIFIED	
				DRAWN BY/DWG. NO. 50/23/08	
				CHECKED/APPROVED/DEC. 500"	
				ANGLE 5	
				SIZE 0	
				SCALE	
				N.T.S.	
				REV A	
				CALIFORNIA • RENO	
				800.486.4858	
				WASHINGTON • OREGON	
				ALASKA • IDAHO • MONTANA	
				888.690.0090	

THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF CHC, CALIFORNIA HYDRONICS CORP. COPIES ARE ISSUED IN STRICT CONFIDENCE AND ARE NOT TO BE REPRODUCED OR COPIED OR USED AS THE BASIS FOR THE MANUFACTURING, INSTALLATION OR SALE OF PRODUCT WITHOUT PRIOR WRITTEN PERMISSION OF CHC.