



Recc all piping to be sized per ASHRAE F36

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM F INLET TEMPERATURE
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF CHC, CALIFORNIA HYDRONICS CORP., AND SHALL NOT BE REPRODUCED OR USED AS THE BASIS FOR THE MANUFACTURING, INSTALLATION OR SALE OF PRODUCT WITHOUT WRITTEN PERMISSION OF CHC.	
PROJECT NAME: PROJECT LOCATION: ENGINEER: CUSTOMER:	DRAWING TITLE: HYDRONIC PRIMARY/SECONDARY - 2 ATMOSPHERIC BOILERS, CIRCUIT SETTER PROTECTION, WITH 2 SYSTEM PUMPS DRAWING No. H-PS-100-2CS-2 PREPARED BY: [Name] [Date] [Signature] CHECKED BY: [Name] [Date] [Signature] TOLERANCES UNLESS OTHERWISE SPECIFIED: SIZE D, SCALE 1/8" = 1'-0"
REV A RELEASED RSG 05/28/08 DESCRIPTION	REV A SCALE 1/8" = 1'-0" CHC CALIFORNIA • RENO 800.486.4858 WASHINGTON • OREGON ALASKA • IDAHO • MONTANA 888.690.0090