



Recc all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM 175°F INLET TEMPERATURE
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

| | | | |
|---|--|---|--|
| PROJECT NAME: | | THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF CHC. IT IS TO BE USED ONLY FOR THE PROJECT SPECIFICALLY IDENTIFIED HEREIN. ANY REPRODUCTION OR USE FOR OTHER PROJECTS WITHOUT WRITTEN PERMISSION OF CHC. | |
| PROJECT LOCATION: | | ENGINEER: RSG 05/28/08 | |
| DRAWING TITLE: | | DATE | |
| HYDRONIC PRIMARY/SECONDARY - 2 SEALED COMBUSTION BOILERS, CIRCUIT SETTER PROTECTION, WITH SYSTEM PUMP | | BY | |
| DRAWING No. H-PS-200-2CS-1 | | DESCRIPTION | |
| DRAWN BY/DATE: BRYAN 05/23/08 | | REV A RELEASED | |
| CHECKED BY/DATE: [blank] [blank] | | REV [blank] [blank] | |
| APPROVED BY/DATE: [blank] [blank] | | [blank] [blank] | |
| SCALE: 500' | | SCALE: [blank] | |
| SHEET: [blank] | | SHEET: [blank] | |
| SHEET SIZE: [blank] | | SHEET SIZE: [blank] | |
| SHEET NO: [blank] | | SHEET NO: [blank] | |
| SHEET TOTAL: [blank] | | SHEET TOTAL: [blank] | |
| SCALE: [blank] | | SCALE: [blank] | |
| SHEET: [blank] | | SHEET: [blank] | |
| SHEET SIZE: [blank] | | SHEET SIZE: [blank] | |
| SHEET NO: [blank] | | SHEET NO: [blank] | |
| SHEET TOTAL: [blank] | | SHEET TOTAL: [blank] | |

