



Recc all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM °F INLET TEMPERATURE
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

PROJECT NAME: PROJECT LOCATION: ENGINEER: CUSTOMER:		THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF FLORENCE SYSTEMS, A DIVISION OF CHC. REPRODUCTION OR USE AS THE BASIS FOR THE MANUFACTURING, WITHOUT PRIOR WRITTEN PERMISSION OF CHC.	
DRAWING TITLE: HYDRONIC PRIMARY/SECONDARY - 4 SEALED COMBUSTION BOILERS, CIRCUIT SETTER PROTECTION, WITH SYSTEM PUMP		DRAWING No. H-PS-200-4CS-1 DRAWN BY/DATE: RSG/05/23/08 CHECKED BY/DATE: [blank]/[blank] APPROVED BY/DATE: [blank]/[blank]	
PROJECT NAME: PROJECT LOCATION: ENGINEER: CUSTOMER:		THIS DRAWING AND THE INFORMATION DEPICTED THEREIN IS THE PROPERTY OF FLORENCE SYSTEMS, A DIVISION OF CHC. REPRODUCTION OR USE AS THE BASIS FOR THE MANUFACTURING, WITHOUT PRIOR WRITTEN PERMISSION OF CHC.	
DRAWING TITLE: HYDRONIC PRIMARY/SECONDARY - 4 SEALED COMBUSTION BOILERS, CIRCUIT SETTER PROTECTION, WITH SYSTEM PUMP		DRAWING No. H-PS-200-4CS-1 DRAWN BY/DATE: RSG/05/23/08 CHECKED BY/DATE: [blank]/[blank] APPROVED BY/DATE: [blank]/[blank]	
REV A RELEASED	DESCRIPTION RSG 05/28/08	BY DATE	DATE

