



Rec all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM °F INLET TEMPERATURE
 BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

PROJECT NAME:		THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE PROPERTY OF CHC, CALIFORNIA HYDRONICS CORP. NO PARTS OF THIS DRAWING OR INFORMATION CONTAINED HEREIN ARE TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT PRIOR WRITTEN PERMISSION OF CHC.	
PROJECT LOCATION:		ENGINEER:	
DRAWING No. H-PS-202-2CS-2		CHECKED APPROVED DEC. 500"	
DRAWN BY/DATE D.K. 05/29/08		SCALE NTS	
REV A		SIZE 0	
DESCRIPTION		DATE	
BY		DATE	
RSG 05/28/08		RSG 05/28/08	
RELEASED		BY	
A		DATE	
REV		DATE	

CALIFORNIA • RENO
 800.486.4858
 WASHINGTON • OREGON
 ALASKA • IDAHO • MONTANA
 888.690.0090