



Rec all piping to be sized per ASHRAE F36.

Note: This drawing shows suggested piping configuration. Check with local codes and ordinances for additional requirements.

*BALANCE VALVE "A" AND "B" TO MAINTAIN MINIMUM °F INLET TEMPERATURE BOILER MUST BE SET FOR ON/OFF FIRING MODE ONLY

| | | | |
|--|-----------------|---|---------------------|
| <p>THIS DRAWING AND THE INFORMATION CONTAINED HEREIN ARE THE PROPERTY OF CHC, CALIFORNIA HYDRAONICS CORP. CONSENT AND SHALL NOT BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT PRIOR WRITTEN PERMISSION OF CHC.</p> | | <p>PROJECT NAME: HYDROVIC PRIMARY/SECONDARY - 3 SEALED COMBUSTION BOILERS, CIRCUIT SETTER PROTECTION, WITH EXTERNAL PRIMARY PUMP STARTER AND 2 SYSTEM PUMPS</p> | |
| <p>PROJECT LOCATION: ENGINEER: CUSTOMER:</p> | | <p>DRAWING No. H-PS-202-3CS-2 TOLERANCES UNLESS OTHERWISE SPECIFIED DRAWN BY/DATE: [blank]/05/29/08 CHECKED/ APPROVED/DEC. [blank] 500" REV A</p> | |
| <p>DESCRIPTION</p> | <p>DATE</p> | <p>BY</p> | <p>RSG 05/28/08</p> |
| <p>REV A</p> | <p>RELEASED</p> | <p>DESCRIPTION</p> | <p>DATE</p> |

